



# Comparing Models and Actual Performance for PV/Diesel Minigrids in Northern Australia

James Hazelton, Anna Bruce, Iain MacGill

Never Stand Still

Faculty of Engineering

School of Photovoltaic and Renewable Energy Engineering

# Contextual Background

- SE4ALL – MGs identified as a High Impact Opportunity (HIO)
- MGs for energy Access up to 40% of new energy access 2010 to 2030
- “undervalued”, cost comparisons to SHS are misrepresentative and detrimental to quality > “Surplus” vs. “Subsistence” power

## Problem Statement

- Renewable Energy is no longer a new technology but still considered risky – Inherent due to high capital cost, and payback contingent on long term operation – Hybridisation also has different risks involved
- Deployment has been slower than predicted, few examples of large scale programmatic development
- Hybrid modelling literature is prolific, there’s a shortage of operational experience that can be used to verify the models and guide decision making.
- Poor performance could result in a backlash and localised market spoilage such as what has been observed in SHS where quality was poor.
- What can be done to better understand and manage risk in these projects?

# Broader Research

The aim of the research project is to:

1. Investigate the operational experience and risk proposition of Photovoltaic/Diesel Mini-grid systems in the Asia Pacific region
2. Recommend ways to mitigate risk and better manage uncertainty in both the ongoing operations of existing programs and expected future project development.



## Broad Research Question

“How can we better model and manage the risks involved in PV mini-grid deployment in the Asia-Pacific?”


# Northern Territory, Australia

- Australia's 3<sup>rd</sup> largest State by land area, yet least populous.
- Power and Water Corporation acts as the State utility provider.
- Under their Not-for-Profit subsidiary, Indigenous Energy Services Pty Ltd (IES), they provide services to over 38,000 people living outside of population centres.
- IES own, operate and maintain 52 isolated electrical mini- grids (combined generation capacity of 76MW).
- Fuel mix historically 88% Diesel (2009)



Image Source: PWC, Wikimedia Commons

Indigenous communities' power, water supply and sewerage services




**Recent Federal Government Australian Renewable Energy Agency (ARENA) funded Projects:**

**TKLN Projects**  
Public Private Partnership  
PPA Model  
3x Low Penetration PV Integrations  
Completed 2013


**Solar Energy Transformation Program (SETuP)**  
Utility Led  
30x Low Penetration PV Integrations  
1x High penetration PV Integrations  
2015-2017

Source: PWC Annual Report (2014)/Solar-Diesel Handbook (2013)





**TKLN Projects**  
 Public Private Partnership  
 PPA Model  
 3x Low Penetration PV Integrations  
 Completed 2013




Source: PWC Annual Report (2014)/Solar-Diesel Handbook (2013)

# TKLN Projects


- Tender awarded to Epuron to install, own and operate fixed tilt PV arrays and short term storage for 'smoothing' of output using lead acid batteries.
- RE plant capacity exceeds 1MWp
  - Kalkarindgi: 402kWp,
  - Ti Tree: 324kWp
  - Lake Nash: 266kWp PV + 45kWp WTG
- Coincided with PWC's replacement of existing diesel power station at Lake Nash which had reached end of life, along with communications upgrades for remote monitoring at all sites.



# Block Diagram - Ti Tree




# Data Analysis – CY13 Ti Tree



## Uncertainty in Project Development

## Uncertainty in Operating Performance



Does the Asset perform as expected?

How do we measure & report performance?

What variables can (should) we forecast?

How do we avoid/

..reduce/


..transfer/

..retain


the risks involved?

Source: RETSCREEN


## RET Integration Project Steps






# Data Analysis – CY13 Ti Tree




# Data Analysis – CY13 Ti Tree – Operating Ranges




Metric	Observed	Homer 'Basic'	Homer 'Calibrated'								
<b>Maximum Instantaneous PV Power Penetration (%)</b>	77%										
<b>Annual RE Energy (%)</b>	18%										
<b>Generator Run hours</b>	 <table border="1"> <caption>Generator Run hours</caption> <thead> <tr> <th>Scenario</th> <th>Run hours</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>3,085</td> </tr> <tr> <td>2</td> <td>5,646</td> </tr> <tr> <td>3</td> <td>340</td> </tr> </tbody> </table>	Scenario	Run hours	1	3,085	2	5,646	3	340		
Scenario	Run hours										
1	3,085										
2	5,646										
3	340										
<b>Generator Starts</b>	 <table border="1"> <caption>Generator Starts</caption> <thead> <tr> <th>Scenario</th> <th>Starts</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>543</td> </tr> <tr> <td>2</td> <td>491</td> </tr> <tr> <td>3</td> <td>109</td> </tr> </tbody> </table>	Scenario	Starts	1	543	2	491	3	109		
Scenario	Starts										
1	543										
2	491										
3	109										
<b>Generator Operating Ranges</b>											
<b>Fuel Reduction</b>	13%										
<b>LCOE \$</b>	N/A										

*...but how to derive fuel reduction?*

7 Days Observed Operation




7 Days ASIM Simulated Operation – Reference Case




*...but how to derive fuel reduction?*

7 Days Observed Operation



7 Days ASIM Simulated Operation – No PV Case






# Homer Modelling – Part 1: Basic Homer Model Comparison

## Comparison 1: Basic Model

What's expected to be known without detailed analysis of site..

### Known Inputs:


- *Site Configuration*
- *Manufacture Specs*
- *2013 Load Data*




Metric	Observed	Homer 'Basic'	Homer 'Calibrated'																
<b>Maximum Instantaneous PV Power Penetration (%)</b>	<b>77%</b>	<b>54%</b>																	
<b>Annual RE Energy (%)</b>	<b>18%</b>	<b>15%</b>																	
<b>Generator Run hours</b>	<table border="1"> <tr><th>Scenario</th><th>Run Hours</th></tr> <tr><td>1</td><td>3,085</td></tr> <tr><td>2</td><td>5,646</td></tr> <tr><td>3</td><td>340</td></tr> </table>	Scenario	Run Hours	1	3,085	2	5,646	3	340	<table border="1"> <tr><th>Scenario</th><th>Run Hours</th></tr> <tr><td>1</td><td>781</td></tr> <tr><td>2</td><td>7,073</td></tr> <tr><td>3</td><td>1,132</td></tr> </table>	Scenario	Run Hours	1	781	2	7,073	3	1,132	
Scenario	Run Hours																		
1	3,085																		
2	5,646																		
3	340																		
Scenario	Run Hours																		
1	781																		
2	7,073																		
3	1,132																		
<b>Generator Starts</b>	<table border="1"> <tr><th>Scenario</th><th>Generator Starts</th></tr> <tr><td>1</td><td>543</td></tr> <tr><td>2</td><td>491</td></tr> <tr><td>3</td><td>109</td></tr> </table>	Scenario	Generator Starts	1	543	2	491	3	109	<table border="1"> <tr><th>Scenario</th><th>Generator Starts</th></tr> <tr><td>1</td><td>510</td></tr> <tr><td>2</td><td>680</td></tr> <tr><td>3</td><td>379</td></tr> </table>	Scenario	Generator Starts	1	510	2	680	3	379	
Scenario	Generator Starts																		
1	543																		
2	491																		
3	109																		
Scenario	Generator Starts																		
1	510																		
2	680																		
3	379																		
<b>Generator Operating Ranges</b>																			
<b>Fuel Reduction</b>	<b>13%</b>	<b>11%</b>																	
<b>LCOE (\$/kWh)</b>	<b>N/A</b>	<b>\$0.29</b>																	

# Data Analysis – Comparison

## 7 Days Observed Operation



## 7 Days Homer Basic Operation



# Homer Modelling – Part 2: Calibrated Homer Model Comparison

## Comparison 2: Calibrated Model


What's expected to be known from detailed operational/development data...

Detailed Feasibility Study




### Known Inputs:

- *Site Configuration*
- *Manufacture Specs*
- *2013 Load Data*
- + *Solar Radiation*
- + *Temperature Data*



# Homer Modelling – Part 2: Calibrated Homer Model Comparison

Comparison of Basic Model and 2013 Observations  
Average Daily Radiation and Clearness Index




*Annual Average ('13 Recorded):*      **6.01 kWh/m²/day**

*Annual Average (NASA SSE):*      **6.08 kWh/m²/day**

# Homer Modelling – Part 2: Calibrated Homer Model Comparison


## Fuel Consumption Curve Comparison: Generator A 450kW




Metric	Observed	Homer 'Basic'	Homer 'Calibrated'																								
<b>Maximum Instantaneous PV Power Penetration (%)</b>	<b>77%</b>	<b>54%</b>	<b>77%</b>																								
<b>Annual RE Energy (%)</b>	<b>18%</b>	<b>15%</b>	<b>16%</b>																								
<b>Generator Run hours</b>	<table border="1"> <tr><th>Scenario</th><th>Run Hours</th></tr> <tr><td>1</td><td>3,085</td></tr> <tr><td>2</td><td>5,646</td></tr> <tr><td>3</td><td>340</td></tr> </table>	Scenario	Run Hours	1	3,085	2	5,646	3	340	<table border="1"> <tr><th>Scenario</th><th>Run Hours</th></tr> <tr><td>1</td><td>781</td></tr> <tr><td>2</td><td>7,073</td></tr> <tr><td>3</td><td>1,132</td></tr> </table>	Scenario	Run Hours	1	781	2	7,073	3	1,132	<table border="1"> <tr><th>Scenario</th><th>Run Hours</th></tr> <tr><td>1</td><td>6,902</td></tr> <tr><td>2</td><td>163</td></tr> <tr><td>3</td><td>1,694</td></tr> </table>	Scenario	Run Hours	1	6,902	2	163	3	1,694
Scenario	Run Hours																										
1	3,085																										
2	5,646																										
3	340																										
Scenario	Run Hours																										
1	781																										
2	7,073																										
3	1,132																										
Scenario	Run Hours																										
1	6,902																										
2	163																										
3	1,694																										
<b>Generator Starts</b>	<table border="1"> <tr><th>Scenario</th><th>Generator Starts</th></tr> <tr><td>1</td><td>543</td></tr> <tr><td>2</td><td>491</td></tr> <tr><td>3</td><td>109</td></tr> </table>	Scenario	Generator Starts	1	543	2	491	3	109	<table border="1"> <tr><th>Scenario</th><th>Generator Starts</th></tr> <tr><td>1</td><td>510</td></tr> <tr><td>2</td><td>680</td></tr> <tr><td>3</td><td>379</td></tr> </table>	Scenario	Generator Starts	1	510	2	680	3	379	<table border="1"> <tr><th>Scenario</th><th>Generator Starts</th></tr> <tr><td>1</td><td>1,046</td></tr> <tr><td>2</td><td>148</td></tr> <tr><td>3</td><td>1,048</td></tr> </table>	Scenario	Generator Starts	1	1,046	2	148	3	1,048
Scenario	Generator Starts																										
1	543																										
2	491																										
3	109																										
Scenario	Generator Starts																										
1	510																										
2	680																										
3	379																										
Scenario	Generator Starts																										
1	1,046																										
2	148																										
3	1,048																										
<b>Generator Operating Ranges</b>																											
<b>Fuel Reduction</b>	<b>13%</b>	<b>11%</b>	<b>14%</b>																								
<b>LCOE (\$/kWh)</b>	<b>N/A</b>	<b>\$0.29</b>	<b>\$0.33</b>																								

# Visual Comparison with Calibrated Model

## 7 Days Observed Operation



## 7 Days Homer Calibrated Operation





# Conclusions

- Homer is an incredibly robust tool for decision makers.
- As with all models it will only be as good as the inputs for the person using it and limitations with less conspicuous performance metrics need to be understood.
- With PV integration we focus on the renewable energy element (so does funding!), however wholistic system impacts and alternative optimisation methods are equally important for success.
- Models such as Homer and ASIM are useful not just in project development, but in Asset Management.
- The NT Context provides an appealing case for retro fitted PV/Diesel applications in a developed context.
- TKLN Projects specifically are a highly innovative undertaking from both a technical and organizational perspective.
- While fuel savings were modest (13%), instantaneous PV penetrations can be as high as 77%. This highlights the design challenge of even a low PV integration.